Dated: 22.06.2013

Amendment No. 1

Tender No. HSCC/KCGMC/PACKAGE-II/2013

Package – II, KCGMC - Tender Pre-bid Meeting held on 19.06.2013

Project Name - Construction of Hospital, OPD & other Associates Works including

dismantling of existing buildings & their foundation for Kalpana Chawla

Govt. Medical College (KCGMC), Karnal, Haryana.

Reply of Bidder's queries raised during Pre-bid meeting held on 19.06.2013 at HSCC, Head Office, Noida.

Sl.No.	Queries	Reply
1.	Bidders requested for extension of submission of bid date.	The Last date to fill/upload the tender through e-tendering shall be 12.07.2013 upto 14:30 hrs opening at 15.00 hrs in place of 02.07.2013 upto 14:30 hrs opening at 15.00 hrs
2.	We request you to pay us interest free mobilization advance in single installment @ 10% of contract value against bank guarantee of equivalent amount.	Shall be as per Tender Condition.
3.	We request you to pay interest free advance towards plant & machineries @ 90% of cost of plant & machinery (new purchase cost or residual value, as the case may be) subject to a maximum of 5% of contract value as per GCC clause no. 10B(iii) against Bank Guarantee of equivalent amount.	Shall be as per Tender Condition.
4.	We request you to accept retention money in the form of Bank Guarantee @ 5% of Contract Price within 15 days of award of work and there shall not be any cash deduction from our RA bills. Kindly confirm.	Shall be as per Tender Condition.
5.	Escalation on Labour component is payable or not? Please confirm.	Shall be as per Tender Condition.
6.	We request you to provide details drawings for utility present at site. Also please confirm that overhead/ underground utilities shall be shifted by client/ owner without any extra cost to us.	The utilities found and required to be shifted, if any will be done by the contractor to whom this construction work is awarded.
7.	We request you to kindly provide the	Has been uploaded with this reply to

	Master Plan mentioning the existing infrastructure proposed construction structures.	bidder.
8.	The project duration is 20 months. Whereas the milestone mentioned in the table are not in consonance with the project duration of 20 months. Kindly look into the same and provide us the revised Milestones commensurating with the project duration of 20 months.	Shall be as per Tender Condition.
9.	We request you to provide Basic Rates of other Major Materials like Cement, Steel Reinforcement, Structural Steel, Bricks, Tiles, Stones etc.	For steel and cement please refer Schedule - 'F' of Vol-II (GCC) as per tender conditions. For other material shall be as per tender condition.
10.	Request you to provide Water and Electricity at one point within the project boundary without any extra cost to us. Further Distribution shall be done by us. You are also requested to give us permission to use the Bore-wells existing in the site.	Contractor has to make their own arrangement for water and power for construction.
11.	We request to provide suitable land for setting up labour colony in the vicinity of site at free of cost to us.	Shall be as per Tender Condition.
12.	Huge no. of Trees (more than 250 nos.) are in the proposed sites and the duration of work is only 20 months. Hence, for tree cutting, you are requested to get the permission/ approval from concern authority.	Shall be as per Tender Condition.
	We presume that all the scheme approvals related to Fire, Lift, Electrical and Master Plan shall be taken by the owner and scope of our approvals shall be based on these approved schemes. Also all necessary assistance shall be provided by the owner/client in obtaining the approval. Kindly confirm.	
13.	Please provide the Soil investigation report.	Please refer tender clause no. 1.17, Vol. I
14.	We request you to consider the value of executed works of similar projects in Govt. sector, even if the work is not fully completed.	Shall be as per Tender Condition.
15.	Kindly provide us the BOQ in Excel Format for our working only.	BOQ in PDF format is available on tender web site.

16.	Do we need to submit Tender documents (Volume-I to IV) online? Please clarify.	All tender documents to be submitted through e-tender as per tender condition.
17.	Please provide us general layout plan of housing package showing all buildings/structures in package-1. This is essential for logistic planning of work.	Site layout plan is uploaded on web site along with this reply.
18.	Please provide us floor wise built-up area of all buildings.	Please refer tender drawings.
19.	This being high valued work having construction period of 20 months. We requested you to make escalation clause 10CC applicable. This will help all bidders to provide you most competitive offer & avoiding unnecessary loading for escalation provision. (Sch F clause 10CC)	Shall be as per Tender Condition.
20.	Labour component is specified 25% of value of work but clause 10C (which takes care of change in wages of labour) is specified as not applicable. We understand it is typographical error. Please review & rectify. (Sch F clause 10C)	Shall be as per Tender Condition.
21.	Please clarify whether Service tax is applicable or not if applicable it is reimbursed or not.	PL. refer tender clause 2.3.7 a. i of Vol. I
22.	Please specify area of site office to be provided to the Client/ his consultants.(SCC- 42.2.5)	Shall be as per Tender Condition.
23.	We request you to consider release Performance Guarantee after completion of work instead of Defect Liability Period. As Security Deposit of 5% of the CP will be there during DLP period. (GCC-Cl. I)	Shall be as per Tender Condition.
24.	We understand land for establishment of site office, store, fabrication year, concrete batching plant etc. will be given free of cost at project site. Please confirm.	Shall be as per Tender Condition.
25.	Please clarify whether bore well for construction water will be permitted at site or not.	Prior permission required to be taken by contactor from concerned authority as applicable.
26.	Please specify whether labour cess shall be deducted by the client.	Labour cess will be directly deposited by contractor to the concerned authority as per prevailing norms.
27.	We understand that list of subcontractors & their credentials to be submitted by successful bidder after award of work. Please confirm.	Shall be as per Tender Condition.
28.	Please confirm whether hardcopy of	Please refer to Note at Annexure-1

	Envelop No.1, 2 & 3 are to be submitted only by online or physically also.	Checklist, Vol. I of tender document.
	In case we need to submit Envelope No. 1, 2, & 3 Physically, we request you to give 3 days time from the date of online submission.	
29.	We will be able to get only labour licence.	Shall be as per Tender Condition.
	As a normal practice all other approvals shall be obtained by the owner. Please confirm.	
30.	We request you to exclude 3 months period from this condition i.e. Vol. III (SCC)- Clause 31 C (ii), Page 42 -75% of the value of the material expected to be consumed within 3 months of its delivery at site for permanent works on the site requirement of works	Shall be as per Tender Condition.
31.	(i) We request you to allow us to submit BG for the second half of the Retention money also (i.e. 2.5%) so that there will not be any cash retention from RA Bills. Also request you to exclude the Alternative clause for the Retention	Shall be as per Tender Condition.
	Money. (ii) Further we request you to release this Retention after completion of the work since Performance Guarantee of 5% of the contract amount submitted at the time of acceptance of the contract shall be valid upto the end of Defects Liability Period.	
32.	We request you to consider the payment for such item as follows. As per the actual rates prevailing in the market for L+M+P+20% towards Contractor's Over Heads & Profits + Taxes + Labour Cess.	Shall be as per Tender Condition.
33	We request you to relax minimum bill value as stipulated in schedule F eligible for payment under clause 7,Vol II of GCC for initial and last 2 RA Bills.	Shall be as per Tender Condition.
34.	Request to provide Elevation & Cross	Has been uploaded on web site along with

	sectional drawings for hospital & OPD	this reply.
35.	Block. Request to provide soft copy of tender drawings to enable us to study it and submit our most competitive & comprehensive bid.	Tender drawings already available at tender web site.
36.	Please clarify that the bidder can offer a common discount considering both the packages are awarded to the same bidder. For this discount separate letter shall be submitted along with the Package II. Please confirm.	Shall be as per Tender Condition. Both are separate tender shall be dealt independently.
37.	Request to modify this clause as given below. The amount which is due in respect of each statement other than the final statement shall be paid as i) 75% of monthly invoice shall be paid within 7 days of from the date of	Shall be as per Tender Condition.
	submission of monthly invoice.ii) Balance 25% shall be paid within 30 days of from the date of submission of Monthly invoice including certification.	
38.	We request you to allow us to submit the hard copy of our bid within 3 days from the last date of submission of bids in online. Kindly confirm.	Shall be as per Tender Condition. Please refer to note at Annexure-I checklist, Vol-I of tender document.
39.	We shall not consider any insurance for the adjacent property around your property. Kindly confirm.	Shall be as per Tender Condition.
40.	We request that we shall be permitted to work on Holidays/ Sundays and during evenings/ nights in order to keep up with the schedule and the supervision shall be extended to us free of cost.	Shall be as per Tender Condition.
41.	Maintenance for 5 Years - We request you to kindly provide us the detailed scope of work and detailed specification for this item of work.	Shall be as per Tender Condition.
42.	Retention money may be deducted from our running bills @ 5% subject to a maximum of 2.5% of the contract value including earnest money which may be encashable against Bank Guarantee(s) as	Shall be as per Tender Condition.

40	and when required by us.	
43.	75% of the payment may be released	Shall be as per Tender Condition.
	within 5 days of the submission of the bill	
	on ad-hoc basis and balance after 10 days	
	subject to the verification.	
44.	We request that the time taken for	Shall be as per Tender Condition.
	dismantling work may be considered	_
	separately.	
45.	The place of Arbitration is not mentioned	Place of arbitration shall be at Chandigarh
10.	here.	only.
46.	Bidders request to issue structural and	Already made available at tender web site.
40.	_	Affeady made available at tender web site.
4.7	architectural drawings for the tender.	
47.	Amount withheld according to the	Shall be as per Tender Condition.
	Mile stone -	
	Bidder request to confirm whether these	
	amounts will be released on achievements	
	of the cumulative Milestones.	
48.	We visited the site and the surroundings,	As per tender condition. Bidders to make
	but we couldn't locate any FALG Bricks	their own survey.
	manufacturers. So you are requested to	
	change the items or provide us the parties	
	who are manufacturing the FALG Bricks	
	in the vicinity of the project.	
49.	We understand that lead above 0.5 Km	Shall be as per tender condition only.
49.		Shan be as per tender condition only.
	will be paid separately. Please confirm.	
	(Item no. 1.06)	
50.	We understand item no. 3.01 is for	Shall be as per tender condition only.
	concrete produced with batching plant	
	erected at site & item no. 3.02 for concrete	
	procured from RMC vendors. Please	
	confirm. (Item no. 3.01)	
51.	Please provide us approved make for	Work shall be carried out as per BOQ
	expansion joint system. (Item no. 3.09 to	item & CPWD Specification.
	3.11)	1
52.	Approved fabricators (i.e. M/s. Ajit (India)	The approved makes given at Sr no. 60 at
22.	Pvt. Ltd./ CALCO/ Alkarma) given for	page-93 of Technical Specification stands
	work are reluctant to quote as scope of	deleted.
		defeted.
	façade work is very less.	Chall ha ag man tau dan an diri
	Please provide us approved make for this	Shall be as per tender condition only.
	item. (Item no. 5.18)	*** 1 1 11 1 1 2 2 2 2 2 2 2 2 2 2 2 2 2
53.	Please provide drawings for this item.	Work shall be carried out as per BOQ item
	Even though unit of SS railing item is in	& CPWD Specification.
	Kg. Approved agencies demanding	
	drawings before giving their offer.	
	Please not that Approved agencies (i.e.	
	Ozone, D-Line, Jindal) given are modular	
	railing agencies & doent do customized	
	Tailing agencies & doon do castonized	

	11: (7) (6.04.0.1) (6.11.1.1)	
	railing. (Item no. 6.04 & list of approved make 52 no.)	
54.	As per approved make 6 mm Dia. is not	Work shall be carried out as per BOQ item
	available. Please allow us to use secondary	& CPWD Specification.
	steel for this item. (Item no. 4.06)	
55.	Please provide us drawings & approved	Work shall be carried out as per BOQ item.
	agency for wall guard. (Item no. 6.05)	
56.	Please provide basic rate of stone flooring	Work shall be carried out as per BOQ item
	items as there are large variation in rates of	& CPWD Specification.
	these items at the time of selection	
	depending on shade, colour, source, size, etc. (Item no. 7.04 to 7.08,7.15)	
57.	Please provide size of ceramic glazed wall	Work shall be carried out as per BOQ item
	tile. Please note that rate of tile varies	& CPWD Specification.
	considerably as size changes. (Item no.	-
	7.11)	
58.	Please provide basic rate of ceramic &	Work shall be carried out as per BOQ item
	vitrified tile flooring. Please note that there	& CPWD Specification.
	are large variation in different series & rate	
	will depend on selection of series at the	
	time of execution. (Item no. 7.11 to 7.14,7.23)	
59.	Please provide basic rate of PVC flooring	Basic rate for PVC Flooring is Rs 100. 00
	& laminated flooring. (Item no. 7.19 &	per sft & Laminated flooring is Rs 175.00
	7.22)	per sft.
60.	Please provide basic rate of glass mosaic	Work shall be carried out as per BOQ item
	flooring. Please note that thee is large	& CPWD Specification.
	variation in rates of glass mosaic tiles	
	starting from 800/sqft to 4000/sqft. (Item	
<u> </u>	no. 7.25)	Work shall be comind out as mor DOO its
61.	Please provide us drawing of dry cladding item. (Item no. 10.01)	Work shall be carried out as per BOQ item & CPWD Specification.
62.	We understand that aluminium framing of	Shall be as per tender condition only.
02.	all structural glazing & ACP cladding	onan oc as per tender condition only.
	items will be paid under item 10.03. Please	
	confirm. (Item no. 10.04 to 10.07)	
63.	Please provide approved agency of	Shall be as per tender condition only.
	signage's work. (Item no. 10.13 to	•
	10.21,10.25)	

64.	Please review rate of this item given in	The following amendments are made in
	BOQ (9.45/sqft). It please review unit of	BOQ for Civil Work:
	this item. (Item no. 10.19)	S.No. Description As As
		per amended BOQ
		1 Qty of Item 400 40
		No. 10.19
		(BOQ Civil)
		2 Rate of Item 81/- 810/-
		No. 10.19 (BOQ Civil)
65.	Please review unit of this item. (Item no.	Unit for item no. 11.07 is "Per centimeter
03.	11.07)	depth per centimeter width per meter
	,	length".
66.	Unit of this item is sqm. We understand	Plinth area of buildings proposed for
	area 11431.23 sqm given is of building	demolition shall be measured for payment
	work only & doesn't consist of roads &	of this item. Nothing extra will be paid for
	footpath.	all other activities mentioned in the BOQ item.
	Please provide us area of road 7 footpath separately. It will enable us estimating	item.
	possible salvage value of serviceable	
	material.	
	Further quantity of this item given in both	
	housing package and hospital package are	
	same. Please review whether these are	
	duplicated. (Item no. 11.22)	
67.	Autoclaved Aerated Cement Blocks - We	Work shall be carried out as per BOQ item
	request you to kindly provide us the	& CPWD Specification.
	approved vendors for this item.	
68.	Aluminium Work - We request you to	Work shall be carried out as per BOQ
	kindly provide us the detailed drawings of	item & CPWD Specification and tender
(0)	this item.	conditions.
69.	Wooden & Fire rated door- We request	Work shall be carried out as per BOQ item
	you to kindly provide us the detailed drawings of this item.	& Technical Specification.
70.	Stainless steel wall Guard- We requests	Work shall be carried out as per BOQ item
, 0.	you to kindly provide us the detailed	& Technical Specification.
	drawings and approved vendors for this	co recimient opermention.
	item.	
71.	We request you to kindly provide the basic	Work Specification, shall be carried out as
	price for tiles, marble and kota stone etc.	per BOQ item & CPWD
	We request you to pay any variation in the	
	basic price during the contract period.	
72.	Acid / Alkali resistant tile - We request	Work Specification. shall be carried out as
	you to kindly provide us the approved	per BOQ item & CPWD
	vendor list for this item.	

73.	Polycarbonate Sheet - We request you to	Work shall be carried out as per BOQ
	kindly provide us the detailed drawings and approved vendors for this item.	item & Technical Specification and tender conditions.
74.	Plastering Work - Kindly confirm whether	Shall be as per Tender Condition Only
	we have to include chicken mesh and proves in our offer? If so kindly provide	
	the details.	
75.		Work Specification. shall be carried out as
	kindly provide us the detailed drawings for this item.	per BOQ item & CPWD and tender conditions.
76.		Work Specification, shall be carried out as
	to kindly provide us the detailed drawings for this item.	per BOQ item & CPWD and tender conditions.
77.	1 1 1 1	
	vendors in the market for the item works mentioned are not providing their rates/	
	quotations.	
	But there are some other reputed agencies	
	also in the market having experience in	
	executing same type of works with adequate quality, who are ready to provide	Shall be as per Tender Condition Only.
	their quotations. Hence, we request you to	Sharr be as per render condition only.
	approve them so that we can quote our	
	rates for the project in appropriate manner and in time.	
	The agencies are:	
	a) For Aluminium works:	
	i) Glaze Technoii) Green Façade	
	iii) Squire Glaze	
	iv) Marvel Touch	
	v) Hatim Glazing vi) Modi Glazing	
	vii)Shreenathji Aluminium Enterprises.	
	b) SS Railing:	
	i) Sialkot	
	We request that the following makes may	
	also be added in the list of approved makes	
	to enable us to quote our bid more competitive:	
	a) Cement : Japee, Shree Cement	
	b) Reinforcement Steel : JSW, JSPL, Jai Balaji	
L	~ w.wj.	

	T	T
	c) Lift Works: Thyssenkrupp, Hyundai	
78.	Please provide module no. of all Sanitary	AS per CPWD Specifications
	wares, fitting & fixtures.	
79.	Sanitary Fitting - As the sanitary Fixtures	AS per CPWD Specifications
	has been the wide range from low end to	
	high end. Request you to provide us the	
	model No. for each item.	
80.	Sanitary Fitting - Please confirm whether it	AS per CPWD Specifications- Floor
00.	is wall mounted or floor mounted as item	mounted closet.
	no. 1.02 & 1.06 calls for floor mounted	mounted closet.
	closet.	
01		CDVC nine CDD 11 class
81.	Water Supply- Kindly provide the pressure	CPVC pipe-SDR-11 class
	class of the pipe i.e. SDR 11 or SDR 13.5	
0.2	(Water S	
82.	Water Supply - Kindly provide the	CPVC pipe-SDR-11 class & GI- Class-B
	pressure class of the pipe. i.e. Schedule.	
83.	Water Treatment Plant - Kindly provide us	AS per BOQ
	the capacity of the plant.	
84.	Soft Water Treatment Plant - Kindly	AS per BOQ
	provide us the capacity of the plant.	
85.	Item No. 3.1 states the use of CPVC pipe	CPVC pipe-SDR-11 class
	but the grade is not mentioned. Kindly	
	specify among SDR11 or SDR 17.	
86.	What type of pumps (Horizontal or	AS per BOQ
	Vertical) can be used for water supply?	
87.	The companies (Kesoram, KDPL)	In list of approved make: plumbing works
	mentioned in the head of cast iron pipes	At Sl.No.7 –Centrifugally/ Sand cast iron
	and fitting IS 3989/1729 do not	pipe & fittings- in Place "Neco, Hepco,
	manufacture the specified item. Kindly	Kesoram, KDPL " Read As " NECO,
	suggest some third brand preferably from	HEPCO, SKF"
	the northern part of India as transportations	
	become easy and supplies can be prompt.	
88.	Sanitary ware - We request you to kindly	AS per CPWD Specifications
00.	provide us the model no. for this item.	115 per er wie opeerneauons
89.	*	AS per ROO
07.	CP Fitting - Approved make is given as	AS per BOQ
	Jaquir. But specification shows PTMT.	
00	Kindly confirm the final one.	CDVC : CDD 11 1
90.	Water Supply - Kindly confirm whether	CPVC pipe-SDR-11 class
0.1	we have quote for SDR 11 or SDR 13.5	OL OL D FOR WATER CARRY
91.	Water Supply - Kindly confirm whether	GI- Class-B FOR WATER SUPPLY
	we have to quote for B class or C class.	
92.	Kindly refer Electrical BOQ Sr. No. 1.01:	ONLY VCB SHALL BE CONSIDERED
	33 kva substation panel outgoing feeder	
	VCB/SF6 both are mentioned in BOQ. But	
	as per technical specification, only VCB	
	panel has been mentioned. Kindly confirm.	
93.	Kindly refer Electrical BOQ Sr. No. 1.04:	TOTAL 18 WAYS SHALL BE
	<u> </u>	_ : :: = = = = = = = = = = = = = = = =

	In HT panel BOQ, it is mentioned 16 way. Whereas as per details BOQ, total no. of ways are 18 ways. Please clarify your requirement.	CONSIDERED INSTEAD OF 16 WAYS.
94.	Kindly refer Electrical BOQ Sr. No. 1.14: As per Bus duct BOQ, approved make are ABB/SCHNEIDER/L&T/GE. But as per approved vendor list, C&S manufacturer name missing. Kindly provide the same.	COSIDER APPROVED MAKE LIST ONLY.
95.	Kindly confirm whether we can consider M.V. panels manufacturer name in Main LT/Syn. DG panel/APFC/AC panels.	AS PER APPOVED MAKE LIST
96.	Kindly refer Electrical BOQ Sr. No. 1.15.14: The unit is mentioned as "each". We feel that the Unit should be "mtr" and not "each". Kindly review and confirm.	METER SHALL BE READ INSTEAD OF EACH
97.	Please refer Electrical Approved Make List at Page 'E-243 R0' (Sl. No. 8 for DG set): It is learnt that the approved manufacturers viz. Cumins, FG Wilson (Perkins),. Caterpiller, MTU are only OEM and not Engine manufacturer. Hence, you are requested to look into the list and provide us revised list, if necessary.	ONLY ENGINE MANUFACTURER SHALL BE CONSIDERED.
98.	Kindly refer Electrical BOQ Sr. No. 4.01: For UPS system, Technical specification and BOQ are not matching neither in terms of rating of UPS. In BOQ, the required is 2x300 KVA UPA. But as per Technical Specification, one no. 550 KVA or 2x257 KVA UPS are to be provided. Kindly clarify.	SPECIFICATION OF ALL RATING SHALL BE SAME AS GIVEN IN BOQ CONSIDERED.
99.	Please provide us the soft copy of drawings with panel SLD (AutoCAD format).	NOT REQUIRED AT THIS STAGE
100.	Please add the name of Dynalite in Approved Make of Lighting control system, as Lutron is single manufacturer name as per specified in BOQ.	Shall be as per tender conditions.
101.	Please refer sub head – 19 lighting fixture Sl. No. 9.02-iv: Cat. No. of light fixture Decon 05CA is not matching as per Decon list. So plese change the cat. No. Decon - 55UB instated of Decon 05CA.	AS PER TENDER
102.	Please refer sub head – 12 Conducting for TV outlet Sl. No. 12.06 : Fabricated of	AS PER TENDER

	DLP U - PVC trunking size is not	
	mentioned in BOQ. Only mention 4/3/2/1	
	way. So kindly requested you that pls. add	
	the size 195x50/ 150x50/ 105x50/ 80x50	
	mm.	
103.	Kindly provide the BOQ, Details of	AS PER TENDER
	battery charger incomer and outgoing	
	feeder, current rating with technical	
104.	specification. Kindly refer sub head 13 of Fire Alarm	PLEASE READ EXCLUDING SONDUIT
104.	System (Sl. No. 13.01 – I & ii) : The	FROM THIS ITEM
	Details mentioned including wire with	TROW THIS ITEM
	conduit but conduit is already taken in	
	Sl.no. 13 of the BOQ. Kindly look into the	
	same and clarify in which conduit is to be	
	considered.	
105.	Kindly refer sub head 20 (Lightning	READ METER INSTEAD OF EACH
	Protection) i. Sr.n- 20.07 : As per BOQ item	
	description, the item is only fixing.	
	Kindly confirm. Also the Unit of the	
	item should be 'meter' instead of	
	'each'. Please clarify.	
106.	ii. Sr.n – 20.08 : As per BOQ item	SAME AS BOQ
	description (cooper strip 20x 3mm),	
	the item is only fixing. Kindly confirm.	
107.	iii. Sr.n-20.09 : The unit of test joint	READ EACH INSTEAD OF METER
107.	should be 'each' instead of 'meter'.	READ EACH INSTEAD OF WIETER
	Please clarify.	
108.	iv. Sr.n- 20.11/12: (Items of GI tape	AS PER BOQ
	32x6mm): Both the items are same	
	i.e. laying in ground. Sr.n- 20.11	
	including providing and laying and	
	Sr.n-20.13 items is again only laying	
	in ground. Please review the items and provide us modified items, if	
	necessary.	
109.	Request you to issue the tender drawings	NOT REQUIRED AT THIS STAGE
	including SLDs and floor layouts for our	
	reference.	
110.	Request you to provide approved makes	AS PER APPROVED MAKE LIST
111	for every items specified for this project.	2 NOS OUTCODIS SULLI DE
111.	33KV HT Panel - 3 Nos. 33/11 KV	3 NOS. OUTGOING SHALL BE
	transformer specified in BOQ. Kindly confirm whether 33 KV HT Panel shall	PROVIDED
	consist of 3 Nos. outgoing feeders to cater	
	1 Tombiot of 5 1 too. Outgoing reducts to cutof	


	these 3 Nos. transformer without any spare	
	breaker in 33 kV HP Panel.	
112.	Item No1.15.22- Cable Tray - Please	AS PER BOQ
	confirm earthing along cable tray is a prt	
112	of this line item or specified elsewhere.	AG PER POO
113.	MV Panel GF (Sec-2) AHU Please	AS PER BOQ
114	confirm whether it is Sec 1 or Sec 2	NOT DECLUDED AT THE CTACE
114.	Lifts - Architectural drawing is not	NOT REQUIRED AT THIS STAGE
115.	available. Request you to furnish the same. Lifts - Kindly confirm whether we have to	AS PER BOQ
113.	consider 4 stops and 4 openings.	AS FER BOQ
116.	HT Substation - 33 KV HT Panel -	3 NO. OUTGOING SHALL BE
110.	Incommer panel is mentioned in VCB but	PROVIDED
	outgoing panel mentioned in VCB/SF6.	TROVIDED
	Please clarify the outgoing panel we have	
	to consider in VCB or SF6.	
117.	HT Sub Station - BOQ one line is merged.	AS PER TENDER
	Please send the BOQ for Excel format.	
118.	HT Sub Station - Please clarify, if we have	EARTHTHED
	to consider Earthed or unearthed.	
119.	Single Line Drawings - Please provide the	NOT REQUIRED AT THIS STAGE
	Electrical Single Line drawing.	
120.	Electrical Transformer - We request you to	AS PER BOQ
	please clarify whether the voltage ratio of	
	OLTC transformer is 33/11 KV or	
	11/0.433 KV (BOQ states – 33/11KV and	
101	tech. specs. States: 11/0.433 KV)	AC PER POO
121.	Electrical Transformer - We request you to	AS PER BOQ
	please clarify whether the cooling of OLTC transformer is ONAN or ONAF	
	(BOQ states : ONAF and Tech. Spec.	
	States: ONAN)	
122.	We request you to accept R123 refrigerant	Shall be as per tender documents.
	based chiller.	and the property of the proper
123.	Pressure rating of evaporator/ condenser	Shall be as per tender documents.
	shall be as per manufacturer standard and	1
	pressure code shall be ASME/GB	
	standard.	
	Cooling coil shall be 0.4 mm thick.	
124.	Inner outer sheet thickness shall be 0.6mm	Shall be as per tender documents.
	GSS.	r r
	Drain shall be 18 G GI	
125.	Drain pan shall be 22 G GI.	Shall be as per tender documents.
126.	We request to accept 10% access motor	Shall be as per tender documents.
	over BHP instead of 25%.	For the second second


127. We request to accept factory fabricated duct. Joining arrangement shall be four bolt TDC type 128. All type of civil e.g. foundation work/ MS frame work/ will or RCC opening shall be in client scope. 129. Power and water for erection, testing and commissioning shall be provide by you free of cost. 130. We request to accept following additional makes. Centrifugal/ Scroll chiller-Daikin/Trane/ York/ Carrier/ Kirlosker AHU/FCU-Waves/ Fdgetech Centrifugal fan-Yalida Grill/ diffuser-Tristar/ Opella Panel-EAP/ KEPL/ SWG 131. Water Chilling Unit - Please confirm whether the Water cooled chillers shall be provided with VSD or without VSD. 132. We understand the AHU's with Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PH-I System -Please confirm the capacity of the PHI System -Please confirm the eapacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 136. Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.				
frame work/ will or RCC opening shall be in client scope. 129. Power and water for erection, testing and commissioning shall be provide by you free of cost. 130. We request to accept following additional makes. Centrifugal/ Scroll chiller-Daikin/Trane/ York/ Carrier/ Kirlosker AHU/FCU-Waves/ Edgetech Air washer-Waves/ Edgetech Centrifugal fan-Yalida Grill/ diffuser-Tristar/ Opella Panel-EAP/ KEPL/ SWG 131. Water Chilling Unit - Please confirm whether the Water cooled chillers shall be provided with VSD or without VSD. 132. We understand the AHU's with Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System of different Blocks. 11.1 for OT's 11.2 for wards 113.6 Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 136. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please provide the Fan Coil Unit Shall be as per tender documents.	127.	duct. Joining arrangement shall be four		
commissioning shall be provide by you free of cost. 130. We request to accept following additional makes. Centrifugal/ Scroll chiller-Daikin/Trane/ York/ Carrier/ Kirlosker AHU/FCU-Waves/ Edgetech Air washer-Waves/ Edgetech Centrifugal fan-Yalida Grill/ diffuser-Tristar/ Opella Panel-EAP/ KEPL/ SWG 131. Water Chilling Unit - Please confirm whether the Water cooled chillers shall be provided with VSD or without VSD. 132. We understand the AHU's with Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 For wa	128.	frame work/ will or RCC opening shall be	Shall be as per tender documents.	
makes. Centrifugal/ Scroll chiller-Daikin/Trane/ York/ Carrier/ Kirlosker AHU/FCU-Waves/ Edgetech Air washer-Waves/ Edgetech Centrifugal fan-Yalida Grill/ diffuser-Tristar/ Opella Panel-EAP/ KEPL/ SWG 131. Water Chilling Unit - Please confirm whether the Water cooled chillers shall be provided with VSD or without VSD. 132. We understand the AHU's with Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.4 C- Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	129.	commissioning shall be provide by you	Shall be as per tender documents.	
whether the Water cooled chillers shall be provided with VSD or without VSD. 132. We understand the AHU's with Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.3 for wards 11.3 for wards 11.3 Fersure or Total Static Pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	130.	makes. Centrifugal/ Scroll chiller-Daikin/Trane/ York/ Carrier/ Kirlosker AHU/FCU-Waves/ Edgetech Air washer-Waves/ Edgetech Centrifugal fan-Yalida Grill/ diffuser-Tristar/ Opella	Shall be as per tender documents.	
Fine/HEPA filters section with discharge plenum shall be of double their type. Please confirm. 133. Heat Recovery Unit- Please provide both supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.3 for wards 11.3 for wards 11.3 Fersure or Total Static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	131.	whether the Water cooled chillers shall be	Shall be as per tender documents.	
supply & return CFM along with required Heat Transfer Efficiency. 134. Heat Reclaim Ventilation Unit - Please provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.3 for wards 136. Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	132.	Fine/HEPA filters section with discharge plenum shall be of double their type.	Shall be as per tender documents.	
provide the Static Pressure of the unit. 135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.3 for wards 136. Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	133.	supply & return CFM along with required	Shall be as per tender documents.	
135. PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards 11.3 for wards 11.3 for wards 136. Please confirm the static pressure of all AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	134.		20 mm w. g.	
AHUs as per the BOQ is External Static Pressure or Total Static Pressure. 137. Split AC- Please confirm the length of Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	135.	PHI- System -Please confirm the capacity of the PHI System for different Blocks. 11.1 for OT's 11.2 for wards		
Refrigerant piping, power cabling & drain piping per unit. 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	136.	Please confirm the static pressure of all AHUs as per the BOQ is External Static	Total static pressure.	
 138. AHU - Please confirm the polyurethane foam insulation density. 139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents. 	137.	Refrigerant piping, power cabling & drain	Shall be as per tender documents.	
139. FCU - Please provide the Fan Coil Unit Shall be as per tender documents.	138.	AHU - Please confirm the polyurethane	Shall be as per tender documents.	
-	139.	FCU - Please provide the Fan Coil Unit	Shall be as per tender documents.	


140.	Pan Type Humidifier - Please confirm the Resin bonded fiberglass insulation thickness.	Shall be as per tender documents.	
141.	AHU- We propose Edgetch/ETA as an additional make. Please approve.	Shall be as per tender documents.	
142.	FCU- We propose Edgetch/ETA as an additional make. Please approve.	Shall be as per tender documents.	
143.	Grilles – Diffusers - We propose Airmaster as an additional make. Please approve.		
144.	Fire Damper - We propose Airmaster as an additional make. Please approve.	Shall be as per tender documents.	
145.	Please provide the Approved Makes list for PHI system.	Same as air ozone.	
146.	No rates are mentioned in BOQ HVAC items – Sub head – Air Handling unit Sl. No. 5.1.34.	Included in item no. 5.2.1 as mentioned in BOQ.	
147.	IT Works - Please provide the approved agencies contact details of Accenture/ Siemens/ TCS/ Infosys/Capgemini.	Bidder has to make their own survey.	
148.	Bidders requested for change in payment terms of HVAC works.	Shall be as per tender conditions.	
149.	MGMS – Please provide approved list of medical gas system.	Shall be as per tender conditions.	
150.	In BOQ diamenssions are not mentioned properly. Please provide diamenssion of Exaust Hood.	Shall be as per tender conditions.	
151.	In BOQ diamenssions are not mentioned properly. Please provide diamenssion of all mentioned item.	Shall be as per tender conditions.	
152.	In BOQ diamenssions are not mentioned properly. Please provide diamenssion of Hot Bain Marie on Castros.	Shall be as per tender conditions.	
153.	In BOQ diamenssions are not mentioned properly. Please provide diamenssion of Dunnage Rack.	Shall be as per tender conditions.	
154.	There is BOQ item for antitermite work we understand antitermite work is not under scope of contract. Please confirm.	Shall be as per tender conditions.	

All other terms and conditions of the tender shall remain unchanged.

(- Sd -) General Manager (Projects) HSCC (India) Ltd., For & on behalf of Director, KCGMC, Karnal (Haryana)







PROJECT

NORTH NOTES

PROPOSED HOSPITAL BLOCK FOR KALPANA CHAWLA GOVERNMENT MEDICAL COLLEGE AT KARNAL, HARYANA

This drawing with all its contents is the sole intellectual property of the Hospital Services Consultancy Corporation (India) Ltd. Copying of this drawing or part thereof,or its use in any form whatsoever without the written permission of HSCC is prohibited.

TITLE

TENDER DRAWING

HOSPITAL BLOCK

ELEVATION C ELEVATION D

KCGMC-60 Drawing. No.		R-0
		Revision
Job. No.	1 : 250 Scale	Date: 29-12-2012
App. By.	Rev. By	Prep. By

ARCHITECT'S SIGNATURE

HSCC

HSCC (INDIA) LIMITED
(A GOVERNMENT OF INDIA ENTERPRISES)

NEW DELHI

INDIA

