

Point wise reply of pre-bid queries of Electrical items:

Sl.No.	Page No.	Tender Item No.	Item description	Clarification
01.			SLD.	SLD will be furnished to the successful bidder.
02.	E5R1-E8 R1	3.01 to 3.08	FRLS PVC insulated wires is mentioned in BOQ but PVC insulated wire is mentioned in specifications.	BOQ item will prevail.
03.	E10R1	4.01 (v)	2*36W and 2*28W T5 Lamp is mentioned	Fitting will be with 2x28 W TL 5 lamps.
04.	E10R1	4.01(vii)	TCW 097, 2*28W HF	Item will be as per BOQ.
05.	E 11R1	4.02 (i)	9 W CFL and 11 W CFL lamp is mentioned.	Bulk head will be with 11 W CFL.
06.	E47 R0		0.5 mm telephone cable in BOW but in specifications 0.61 is mentioned	BOQ item will prevail.
07.	E-47R0		List of approved manufacturers: S.n. 1 to 7 is missing.	Item nos. 1 to 7 of list of approved manufacturers are not in the scope of contract therefore no make is specified.
08.	E16 R1		0.7 mm tinned copper telephone cable	Item is not of telephone cable it is Coaxial TV cable RG6.
09.		13.01	<u>PVC sheathed cables</u>	XLPE – IS:7098 is acceptable.
10.			List of approved manufacturers- MV Panels (Floor Panels)	CPRI approved manufacturers is acceptable.

All other terms & conditions of bid documents shall remain unchanged.