



# TERRACE FLOOR PLAN

S.NO.	DESCRIPTION	SIMBAL
1.	FIRE HOSE CABINET (FHC) (SIZE: 1200x600x210 Ht)	
2.	SPRINKLER (PENDENT TYPE)	
3.	SPRINKLER PIPE	
4.	INSPECTION TEST VALVE ASSEMBLY (ITV)	
5.	NON RETURN VALVE	
6.	SLUICE VALVE	
7.	FIRE LINE	

  

FIRE EXTINGUISHER	
WATER TYPE FIRE EXTINGUISHER	
CARBON DIOXIDE TYPE FIRE EXTINGUISHER	
MANUAL CALL BOX	

**NOTES ON FIRE FIGHTING**

- Every FHC shall be consisting of as per IS the following:
  - 63mm dia. single headed hydrant valve.
  - 63mm dia. dia. 15m long HRC. hose reel.
  - Down to 36.5m first use hose reel with 5m bore.
  - 63mm dia. male and female INST type coupling.
  - Down to branch pipe with 20m nozzle.
- 2 NOS FIRE EXTINGUISHERS

REV	DATE	DESCRIPTION
REVISION		

**PROJECT**  
 NRHM PROJECT  
 Proposed 100 Bedded Hospital at ALIGARH

**TITLE** PLUMBING

**TENDER DRAWING**  
 TERRACE PLAN

Drawing No.		
Job No.	Scale	Date
App by	Rev. by	Prep. by

**HSCC (INDIA) LIMITED**  
 (A GOVERNMENT OF INDIA ENTERPRISES)

# HSCC

NEW DELHI INDIA